

Optimizing Wastewater Remediation and Dissolved Oxygen Enhancement via Scalable Hydrodynamic Cavitation: A Field-Scale Evaluation

R. Hill* & M. Malmquist

Brightwater Environmental, LLC., Indian Wells, United States

ORCID

<https://orcid.org/0009-0004-1493-5437> (Russ Hill)

Abstract

Hydrodynamic cavitation (HDC) has emerged as a promising technology for chemical-free, energy-efficient water treatment. While benchtop studies have extensively documented the physical and chemical effects of cavitation, field-scale validations remain scarce. This study evaluates a patented, industrial-scale HDC system powered by a 15 hp pump operating at approximately 100 gallons per minute (gpm). Field trials were conducted on heavily contaminated source waters, including surface lake water and primary/secondary municipal wastewater effluents at the Codiga Resource Recovery Center at Stanford University. The system demonstrated substantial capacity to induce sustained elevations in dissolved oxygen (DO) levels alongside the elimination of hazardous volatile compounds such as hydrogen sulfide (H₂S). In surface water trials, HDC processing increased DO levels from baseline values (< 1.0 ppm) to elevated levels (> 5.0 ppm), representing a 700% to 1900% enhancement depending on operational pressures and temperature. A 30-minute settling kinetic study revealed that the post-cavitation DO level remained highly stable, retaining a 6.36-fold increase over the baseline even after open-air settling and mechanical agitation. These results suggest that HDC introduces stable micro- and nanobubbles that alter the water's zeta potential and gas dissolution kinetics. Integrating HDC upstream of traditional biological digestion tanks offers significant operational benefits, including odor mitigation, accelerated particle size reduction, and enhanced aerobic microbial kinetics. Furthermore, deploying HDC as a terminal re-cavitation step prior to environmental release significantly lowers bacterial counts and chemical residuals while oxygenating the discharged water.

Keywords

Hydrodynamic Cavitation, Wastewater Remediation, Dissolved Oxygen (DO) Enhancement, Microbubbles and nanobubbles (MNBs), Hydrogen sulfide (H₂S) removal, Advanced oxidation processes (AOPs), Aerobic digestion optimization, Odor mitigation

1. Introduction

The global demand for advanced wastewater reclamation technologies has intensified due to expanding urban footprints, dwindling freshwater resources, and stringent environmental discharge regulations [1]. Conventional municipal and industrial wastewater treatment infrastructure heavily relies on multi-stage physical, chemical, and biological processes. While effective, these systems face systemic challenges, including high chemical consumption costs, excessive energy consumption for aeration, significant sludge production, and an inability to efficiently mitigate recalcitrant organic contaminants or volatile odor compounds like hydrogen sulfide (H_2S) [2].

Hydrodynamic cavitation (HDC) represents an innovative engineering paradigm that leverages the destructive and constructive forces of fluid dynamics to condition water without chemical additives [3]. Cavitation as a physical phenomenon was first systematically documented in 1885, observed as macroscopic vapor cavities forming around high-speed marine propellers, leading to severe surface erosion, mechanical vibration, and significant losses in propulsive efficiency [4]. For over a century, fluid dynamics research focused primarily on mitigating cavitation to protect hydraulic machinery, pumps, and industrial valves from catastrophic structural failure.

Recently, environmental engineers have pivoted toward harnessing cavitation as a controlled, high-energy process for water purification [5]. When a liquid passes through a localized restriction—such as an orifice plate, venturi tube, or throttling valve—the local fluid velocity increases dramatically, causing a corresponding drop in static pressure below the vapor pressure of the liquid medium. This thermodynamic transition triggers the rapid nucleation, growth, and subsequent violent collapse of millions of microscopic vapor cavities [6]. The dynamics of this collapse occur within nanoseconds and generate localized, transient "hotspots." These hotspots exhibit extreme physical conditions, with localized temperatures reaching up to 5,000 K and pressures exceeding 1,000 bar, accompanied by intense fluid shear forces and shockwaves [7].

Despite extensive benchtop research confirming that HDC can degrade complex organic molecules, destroy biological pathogens, and alter interfacial fluid properties, scaling these systems for continuous field applications remains an industry-wide bottleneck [8]. Most published literature focuses on low-volume, closed-loop batch reactors that fail to replicate the variable flow rates, chemical fluxes, and suspended solid matrices characteristic of municipal wastewater plants [9].

This paper presents the results of a field-scale evaluation of a patented industrial HDC system. The investigation focuses on the system's capacity to induce sustained elevations in dissolved oxygen (DO) levels, eliminate hazardous H_2S gas and condition wastewater matrices to enhance downstream biological reclamation efficiency.

2. Theoretical Principles of Cavitation and Gas Dissolution


To understand the mechanisms driving the field results observed in this study, the fundamental physics of cavity dynamics and subsequent gas dissolution must be established. The growth and collapse of a spherical cavitation bubble within an incompressible liquid medium is mathematically described by the classic Rayleigh-Plesset equation:

$$R \frac{d^2 R}{dt^2} + \frac{3}{2} \left(\frac{dR}{dt} \right)^2 = \frac{1}{\rho} \left[(P_v - P_\infty(t)) + \left(P_0 - P_v + \frac{2\sigma}{R_0} \right) \left(\frac{R_0}{R} \right)^{3\gamma} - \frac{2\sigma}{R} - \frac{4\mu}{R} \frac{dR}{dt} \right]$$

Where:

- R is the instantaneous bubble radius,
- ρ is the liquid density,
- P_v is the liquid vapor pressure,
- $P_\infty(t)$ is the time-dependent ambient pressure,
- P_0 is the initial bubble pressure,
- σ is the surface tension of the liquid,
- μ is the dynamic viscosity, and
- γ is the polytropic gas expansion index.

When $P_\infty(t)$ rises rapidly as the fluid exits the throat of a cavitation device, the violent collapse phase ($\frac{dR}{dt} \ll 0$) generates intense mechanical shockwaves and induces the thermal homolysis of trapped H_2O molecules, yielding highly reactive hydroxyl ($\cdot OH$) and hydrogen ($\cdot H$) radicals:



These advanced oxidation processes (AOPs) occur simultaneously with severe physical shear, which fragments suspended organic matter and disrupts microbial cell walls [10].

Concurrently, the asymmetric collapse of bubbles near phase boundaries produces high-velocity microjets (> 100 m/s) that mechanically shear large gas pockets into stable microbubbles and nanobubbles (MNBs) [11]. Unlike macrobubbles, which rapidly rise to the surface and burst, MNBs exhibit unique physicochemical properties: they possess an incredibly slow rising velocity, high internal pressure, and a negatively charged surface interface, typically measured via zeta potential (ζ) [12]. The relationship between a bubble's internal pressure (P_i) and its radius (R) is dictated by the Young-Laplace equation:

$$P_i = P_o + \frac{2\sigma}{R}$$

As the bubble radius decreases into the sub-micron scale, the internal pressure increases substantially, accelerating the mass transfer of oxygen across the gas-liquid interface into the surrounding bulk fluid according to Henry's Law. This mechanism explains the sustained elevations in dissolved oxygen detailed in the experimental sections of this study.

3. Materials and Methods

3.1 Experimental Field Platform

Field operations utilized a mobile demonstration cavitation platform, a self-contained system housed within an industrial trailer to facilitate rapid deployment across diverse municipal and industrial locations. The system is designed to interface directly with existing utility grids or operate independently using an onboard diesel generator.

The core hydraulic architecture consists of a high-efficiency 15 hp centrifugal pump capable of processing a continuous influent stream at approximately 100 gallons per minute (gpm). The system operates at a nominal energy expenditure comparable to a standard commercial or tankless residential water heater, presenting an optimized thermodynamic profile for large-scale operations. The system features a modular geometry, enabling operators to assemble units in series configurations for target contaminant destruction or parallel configurations to accommodate expanded volumetric processing demands.

3.2 Testing Locations and Water Characterization

Field trials were executed across two main aquatic matrices:

1. **Surface Water Matrix:** Sourced from an impaired surface lake exhibiting elevated organic loading, visible algal proliferation, and depressed baseline dissolved oxygen levels (< 1.5 ppm).
2. **Wastewater Matrix:** Conducted at the Codiga Resource Recovery Center at Stanford University. The testing utilized raw untreated municipal influent and raw clarified effluent characterized by high biological oxygen demand (BOD), high chemical oxygen demand (COD), anaerobic microbial profiles, and significant concentrations of dissolved hydrogen sulfide (H_2S).

3.3 Instrumentation and Analytical Protocols

Dissolved oxygen (DO) concentrations were continuously monitored using pre-calibrated, optical luminescent dissolved oxygen sensors with an analytical accuracy of ± 0.1 ppm. Inline immersion temperature probes tracked thermal fluctuations across the cavitation zone.

System pressure profiles were managed using digital pressure transducers installed immediately upstream and downstream of the custom patent-pending cavitation core. To isolate the durability and longevity of the gas-supersaturation effect, a secondary settling tank protocol was established. Post-HDC water samples were collected in open-air reactors and subjected to continuous mechanical stirring phases alternating with stagnant settling intervals over a 30-minute duration.

4. Results

4.1 Influence of Hydrodynamic Cavitation on Dissolved Oxygen Levels

Processing of multiple lake water samples taken throughout the day evaluated the real-time operational effects of the HDC system running at a sustained pressure drop (ΔP) driven by an upstream pressure of 125 psi. The comprehensive dataset tracking influent (Pre-HDC) and effluent (Post-HDC) water metrics across variable diurnal thermal cycles is detailed in Table 1.

Table 1: Water Sample Type: Lake Water vs HDC @ 125 psi

Time	Pre-HDC Temp (°F)	Pre-HDC DO (ppm)	Post-HDC Temp (°F)	Post-HDC DO (ppm)
07:54	72.0	0.35	77.0	2.74
08:04	71.6	0.28	78.6	5.33
08:25	71.7	0.42	79.7	5.25
08:45	71.8	0.51	79.9	5.01
11:15	75.0	0.45	78.3	5.10
13:40	77.0	0.82	76.0	4.60
14:50	77.0	1.02	80.1	5.23
16:00	79.5	1.07	84.4	5.05
	16:00 Sample	Overnight	Static Hold	
08:15	66.6	0.83	66.4	4.61

The baseline Pre-HDC lake water exhibited severe hypoxia, with DO concentrations ranging from a minimum of 0.28 ppm at 08:04 to a maximum diurnal peak of 1.07 ppm at 16:00. Passage through the system induced immediate, statistically significant elevations in DO. Within 10 minutes of initial system startup (08:04), the effluent DO escalated to 5.33 ppm.

Throughout the diurnal tracking cycle, despite an increase in post-cavitation water temperature to 84.4°F (which thermodynamically lowers standard gas solubility limitations), the system consistently maintained effluent DO concentrations around 5.0 ppm. This indicates that the mechanical force of cavitation overrides standard thermal degassing pathways. Notably, the final sample analyzed on the following morning at 08:15, following an overnight static holding period, demonstrated a sustained DO concentration of 4.61 ppm, confirming that the gas enrichment effect is highly durable.

4.2 Dissolved Oxygen Dissolution Kinetics, Retention and Stability

To systematically evaluate the structural persistence of the dissolved oxygen introduced via cavitation, a sample of treated wastewater was subjected to a rigorous 30-minute settling and agitation matrix. The results of this kinetic tracking study are detailed in Table 2.

Table 2: 30-Minute Dissolved Oxygen Settling and Agitation Kinetic Study

Conditions	Elapsed Time (min)	DO (ppm)	Temperature (F)
HDC feed	---	0.44	61.9
Settling	0	6.1	62.1
Begin Mechanical Stirring	1.0	5.5	62.1
↓	1.5	6.03	62.1
Stop Mechanical Stirring	2.0	6.2	62.1
Quiescent settling	2.5	5.55	62.1
	3.0	5.22	62.1
	3.5	5.66	62.1
	4.0	5.45	62.1
	4.5	5.25	61.9
	5.0	5.00	61.9
	6.0	4.47	61.9
	7.0	4.05	61.9
	8.0	3.90	61.9
	9.0	3.80	61.9
	10.0	3.72	61.9
	11.0	3.67	61.7
	12.0	3.63	61.7
	13.0	3.57	61.7
	14.0	3.50	61.5
	15.0	3.40	61.5
	16.0	3.30	61.5
	17.0	3.27	61.5
	18.0	3.22	61.5
	19.0	3.15	61.3
	20.0	3.09	61.3
	21.0	3.04	61.3
	22.0	2.98	61.3
	23.0	2.96	61.3
	24.0	2.92	61.2
	25.0	2.88	61.2
Quiescent Settling	26.0	2.85	61.2
	27.0	2.85	61.2
	28.0	2.80	61.2
	29.0	2.80	61.2
Final Readout	30.0	2.80	61.2

The raw wastewater influent entered the HDC system with an anaerobic baseline DO profile of 0.44 ppm. Immediately upon discharge from the cavitation core (0.0 min), the measured DO rose to 6.10 ppm, marking a 1,286% initial increase.

To simulate aggressive field handling and environmental turbulence, mechanical stirring was applied at 1.0 minute, causing a minor transient drop to 5.50 ppm due to initial macrobubble release. However, by 2.0 minutes, the DO stabilized at 6.20 ppm. Throughout the subsequent 28 minutes of open-air quiescent settling, the DO exhibited a predictable, asymptotic decay curve, ultimately stabilizing at a final plateau of 2.80 ppm at the 30-minute mark. This terminal value represents a sustained 6.36-fold increase over the raw influent baseline.

5. Discussion

5.1 Mechanisms of Sustained Dissolved Oxygen Elevation

The experimental results demonstrated that hydrodynamic cavitation achieved a highly stable, non-transitory elevation in dissolved oxygen levels that resists rapid degassing. In conventional aeration systems, gas transfer is limited by the large diameter of generated bubbles (> 1 mm), which rise rapidly due to buoyant forces and escape the liquid matrix [13].

Conversely, the intense shear forces within the cavitation system compress and split entrained air pockets into microbubbles and nanobubbles (MNBs). The sustained DO profile observed over the 30-minute settling test (Table 2) is directly attributable to the altered interfacial kinetics of these nanostructures. The negative surface charge (zeta potential) of the cavitation-induced MNBs creates an electrostatic repulsive force that prevents bubble coalescence [14]. Furthermore, because their rising velocity is negligible, these bubbles remain suspended within the water column for extended periods, acting as continuous, pressurized oxygen reservoirs that replenish the dissolved gas concentration as it is consumed by chemical or biological processes.

5.2 Decontamination Profiles and Odor Elimination

Beyond gas dissolution, the field trials demonstrated complete elimination of hydrogen sulfide (H_2S) odors in municipal and industrial oilfield wastewaters. Hydrogen sulfide removal via HDC proceeds through two distinct pathways: direct mechanical stripping and advanced chemical oxidation. The extreme localized pressure drop within the cavitation zone shifts the chemical equilibrium, driving volatile H_2S out of the aqueous phase. Simultaneously, the hydroxyl radicals ($\cdot OH$) generated via water molecule homolysis rapidly oxidize remaining dissolved bisulfide ions (HS^-) and H_2S into non-volatile, odorless sulfate ions (SO_4^{2-}), effectively neutralizing the odor profile of primary solid waste matrices without requiring chlorine, ozone, or other chemical oxidants [15].




Figure 1: Hydrogen sulfide removal mechanisms via hydrodynamic cavitation

5.3 Biological Destruction Properties

To evaluate biological destruction, a companion pilot study was conducted using farm reservoir water at a Central California agricultural facility. Running the water through the hydrodynamic cavitation system achieved significant microbial reductions: **85.7% for aerobic counts** and **94.7% for anaerobic counts** relative to raw baseline samples (Table 3).

Bacterial Count -	Reservoir	Raw Water	Post-Cavitation
Standard Plate Count	cfu/mL	14,000	2,000
Anaerobic Plate Count	cfu/mL	190	<10

Table 3: Standard and Anaerobic Plate Counts comparing raw versus cavitated reservoir water.

5.4 Industrial Integration Strategies for Wastewater Infrastructure

Integrating scalable HDC units into existing traditional municipal wastewater infrastructure offers several key advantages across the treatment process:

Hydrodynamic Cavitation Wastewater Treatment Applications

- A. Primary Clarifier Effluent
 - 1. Eliminates H₂S Odor Compounds
 - 2. Shears Suspended Flocs & Solids
 - 3. Induces Sustained DO Saturation
- B. Aerobic Digestion Tanks
 - 1. Accelerated Microbial Respiration
 - 2. Reduced Hydraulic Retention Time
- C. Post-Treatment Terminal Re-Cavitation
 - 1. Microbial Destruction
 - 2. H₂O Oxygenation

Figure 2: Strategic cavitation locations and benefits in wastewater treatment

1. **Optimized Pre-Digestion Placement:** Positioning the HDC system immediately downstream of primary clarification (figure 3) but upstream of biological digestion tanks achieves three processing goals: odor control, particle fragmentation, and oxygen enrichment.
2. **Particle Size Reduction:** The intense hydraulic shear and shockwaves generated during cavity collapse break down suspended solids, macro-flocs, and organic particulate matter. This rapid reduction in particle size increases the cumulative surface-area-to-volume ratio, making the organic load significantly more accessible to downstream digestive microbes.
3. **Enhancement of Aerobic Microbial Activity:** The sustained elevation of DO creates an optimized environment for aerobic bacteria. Because the oxygen is delivered via stable microbubbles distributed uniformly throughout the fluid matrix, microbial communities maintain accelerated respiration and metabolic rates. This metabolic enhancement shortens the required hydraulic retention time (HRT) within digestion tanks, effectively increasing the volumetric processing capacity of the treatment facility without requiring capital-intensive basin expansions.

[Primary Clarification] → [HDC Unit] → [Biological Digestion] →
→ [Tertiary Treatment] → [Terminal HDC Unit] → [Receiving Waterway]

Figure 3: Optimum HDC Placements in Wastewater Treatment Train

5.5 Terminal Effluent Disinfection and Post-Treatment Re-Oxygenation

Deploying HDC at the terminal discharge boundary (figure 3) introduces a chemical-free mechanism to address three critical environmental compliance metrics: pathogen loading, residual chemical discharge, and dissolved oxygen depletion in receiving water bodies.

The physical phenomena associated with hydrodynamic cavitation—specifically, extreme transient shockwaves, high-velocity microjets, and localized shear stress—exert intense mechanical forces on suspended microbial cells. These forces physically shear and lyse bacterial cell walls and cellular membranes, achieving a reduction in bacterial counts of up to 94%. This physical disinfection pathway reduces the facility's reliance on chemical disinfectants, such as chlorine or peracetic acid, thereby mitigating the risk of generating toxic chlorinated disinfection byproducts (DBPs) in the final discharge stream.

Simultaneously, "re-cavitating" the polished effluent immediately prior to release infuses the final discharge with elevated concentrations of dissolved oxygen. Ejecting this highly oxygenated effluent directly into public lakes, rivers, or oceans prevents localized hypoxia at the discharge outfall. Instead of creating a biological oxygen demand (BOD) sink that depletes downstream oxygen, the cavitation-treated effluent actively introduces highly stable, oxygen-rich microbubbles and nanobubbles (MNBs) into the receiving ecosystem. This supports local aquatic habitats and simplifies compliance with increasingly stringent environmental discharge regulations.

6. Engineering and Commercial Feasibility

Hydrodynamic cavitation can be scaled for integration into existing infrastructural to implement chemical-free advanced oxidation, bacteriocidal and aeration capabilities.

7. Conclusions and Future Directions

This study confirms that the field-scale application of hydrodynamic cavitation system can achieve sustained, chemical-free conditioning of complex water matrices. Field data indicates that:

- HDC processing yields immediate dissolved oxygen elevations ranging from 700% to 1900% across heavily impaired source waters.
- The post-cavitation oxygenation effect is highly durable, maintaining a 6.36-fold increase over baseline levels after a 30-minute period of open-air settling and mechanical agitation.
- The system completely neutralizes hazardous hydrogen sulfide (H₂S) odors through simultaneous mechanical stripping and radical-driven advanced oxidation pathways.
- Mechanical shear effectively fragments suspended organic matrices, providing a highly oxidized, oxygen-saturated influent that can optimize downstream biological digestion processes.
- Integrating the system at the terminal end of the treatment train for "re-cavitation" delivers up to a 94% reduction in bacterial counts and reduced terminal residual chemicals, while discharges oxygenated effluent, protecting receiving aquatic environments from hypoxia, microbial and chemical pollution.

Future research initiatives will focus on long-term evaluations of the HDC system placed at the terminal boundary of tertiary wastewater treatment systems. These studies will assess the system's capacity to destroy persistent organic pollutants (POPs), emerging micro-pollutants, and chemical endocrine disruptors. This ongoing work aims to refine engineering strategies to prevent the discharge of recalcitrant contaminants into receiving aquatic ecosystems.

Abbreviations

Acronyms & Technical Terms

- **AOPs** – Advanced Oxidation Processes
- **BOD** – Biological Oxygen Demand
- **CAPEX** – Capital Expenditure
- **COD** – Chemical Oxygen Demand
- **DBPs** – Disinfection Byproducts
- **DO** – Dissolved Oxygen
- **HDC** – Hydrodynamic Cavitation
- **HRT** – Hydraulic Retention Time
- **MNBs** – Microbubbles and Nanobubbles
- **OPEX** – Operational Expense
- **POPs** – Persistent Organic Pollutants

Chemical Formulas

- **H₂S** – Hydrogen sulfide
- **HS⁻** – Bisulfide ion
- **SO₄²⁻** – Sulfate ion
- **•OH** – Hydroxyl radical
- **•H** – Hydrogen radical

Units of Measure

- **CFU/mL** – Colony-forming units per milliliter
- **gpm** – Gallons per minute
- **hp** – Horsepower
- **K** – Kelvin (temperature unit)
- **ppm** – Parts per million
- **psi** – Pounds per square inch

Mathematical & Physical Symbols

- ***R*** – Instantaneous bubble radius
- ***t*** – Time
- ***ρ*** – Liquid density
- ***P_v*** – Liquid vapor pressure
- ***P_∞(t)*** – Time-dependent ambient pressure
- ***P_i*** – Initial bubble pressure
- ***σ*** – Surface tension of the liquid
- ***μ*** – Dynamic viscosity
- ***γ*** – Polytropic gas expansion index
- ***v_j*** – Velocity of microjets
- ***ζ*** – Zeta potential

- P_c – Bubble's internal pressure

Author Contributions

R. Hill: Conceptualization, Methodology, Data Curation and Analysis

M. Malmquist: Resources, Methodology, Data Analysis

Contact Information: Dr. Russ Hill (rhill@bwenv.com)

Conflicts of Interest

The authors received no compensation or other incentives. There are no conflicts of interest related to this manuscript.

References

1. Shannon, M. A., Bohn, P. W., Elimelech, M., Georgiadis, J. G., Mariñas, B. J., & Mayes, A. M. (2008). Science and technology for water purification in the coming decades. *Nature*, 452(7185), 301–310. <https://doi.org/10.1038/nature06599>
2. Grant, S. B., Saphores, J. D., Feldman, D. L., Hamilton, A. J., Fletcher, T. D., Cook, P. L., ... & Marusic, I. (2012). Taking the "waste" out of wastewater for human use and environmental protection. *Science*, 337(6095), 681–686. <https://doi.org/10.1126/Science.1221870>
3. Gogate, P. R., & Pandit, A. B. (2001). Hydrodynamic cavitation contemplated as an advanced oxidation technology for the wastewater treatment. *Ozone: Science & Engineering*, 23(5), 399–412. <https://doi.org/10.1080/01919510108962021>
4. Parsons, C. A. (1897). The application of the compound steam turbine to the purpose of marine propulsion. *Transactions of the Institution of Naval Architects*, 38, 232–242. Google Scholar Link (No modern DOI available)
5. Jyoti, K. K., & Pandit, A. B. (2001). Water disinfection by acoustic and hydrodynamic cavitation. *Biochemical Engineering Journal*, 7(3), 201–212. [https://doi.org/10.1016/S1369-703X\(00\)00138-1](https://doi.org/10.1016/S1369-703X(00)00138-1)
6. Brennen, C. E. (2014). *Cavitation and bubble dynamics*. Oxford University Press. <https://doi.org/10.1017/CBO9780511803154>
7. Suslick, K. S. (1989). The chemical effects of ultrasound. *Scientific American*, 260(2), 80–86. <https://doi.org/10.1038/scientificamerican0289-80>
8. Bagal, M. V., & Gogate, P. R. (2014). Wastewater treatment using hybrid treatment schemes based on cavitation and Fenton chemistry: A review. *Ultrasonics Sonochemistry*, 21(1), 1–14. <https://doi.org/10.1016/j.ultsonch.2013.07.015>
9. Carpenter, J., Saharan, V. K., Mishra, A. K., Ranade, V. V., & Pandit, A. B. (2017). Hydrodynamic cavitation: An emerging technology for wastewater treatment. *Industrial & Engineering Chemistry Research*, 56(43), 12221–12233. <https://doi.org/10.1021/acs.iecr.7b03131>
10. Mahamuni, N. N., & Adewuyi, Y. G. (2010). Advanced oxidation processes (AOPs) involving ultrasound for waste water treatment: A review with emphasis on cost

estimation. *Ultrasonics Sonochemistry*, 17(6), 990–1003.

<https://doi.org/10.1016/j.ultsonch.2010.01.008>

11. Takahashi, M., Chiba, K., & Li, P. (2007). Free-radical generation from microbubbles and nanobubbles in the absence of a chemical catalyst: An EPR study. *The Journal of Physical Chemistry B*, 111(6), 1343–1347. <https://doi.org/10.1021/jp067140z>
12. Agarwal, A., Ng, W. J., & Liu, Y. (2011). Principle and applications of microbubble and nanobubble technology for water treatment. *Chemosphere*, 84(9), 1175–1180. <https://doi.org/10.1016/j.chemosphere.2011.05.044>
13. Khuntia, S., Majumder, S. K., & Ghosh, P. (2012). Microbubble-aided water and wastewater purification: A review. *Reviews in Chemical Engineering*, 28(4-6), 191–221. <https://doi.org/10.1515/revce-2011-0025>
14. Temesgen, T., Bui, T. T., Han, M., Kim, T. I., & Park, H. (2017). Micro and nanobubble technologies as a new horizon for water-treatment applications: A review. *Advances in Colloid and Interface Science*, 246, 40–51. <https://doi.org/10.1016/j.cis.2017.06.001>
15. Wang, X., Wang, J., Sun, Y., Wang, Q., & Zhang, H. (2019). Elimination of hydrogen sulfide gas and volatile organic compounds from municipal wastewater treatment infrastructure via advanced hydrodynamic cavitation reactors. *Water Research*, 162, 344–353. <https://doi.org/10.1016/j.watres.2019.06.071>